



TRAVELLING REPORT

Date : 28.12.24

Report To		
Employee Name		Aye Thandar Soe, Kyi Kyi Win, Aung & Thu
Position		DH, DH, Section Head
Department		Spec Prod, Unit, Service
Business		PG
Departure & Arrival	Departure Date And Time	Arrival Date And Time
	17.12.24	24.12.24
Total Days		
Trip Information	1. From YAN To MAW	
	2. From To	
	3. From To	
Purpose For Travelling		To know BR market condition, old customer visit and mic inspection, BR & customer relation, how to support to get order
Travel Date	Ground stock checking. Activities	Remark
17.12.24	Departure from YAN (6:00)am Arrived to MAW (6:00)pm	- Customer feedback is good.
18.12.24	- Go to Point Phyat	- Not have reminder card
19.12.24	- Go to salin - come back to MAW	- We advised to use the motor filter instead used other filter.
20.12.24	- MAW down town customer visit.	Unit prospect (8 units) + U. Thiri-Oo (250KVA) + Shwe Nadi (250KVA) + U Htan Hta (200KVA) + U Win Tun (100KVA) + U Shwe Win Tun (200KVA) + U Zaw Min (80KVA) + U Aung Toe (100KVA) + U Htay Lwin (80KVA)
21.12.24	- Go to Aunglan, Pyay	

Reported by

Checked by

Approved by

Sign :

Name : Aye Thandar Soe

Position : DH

Sign :

Name :

Position :

(DH/AGM/GM)

Sign :

Name :

Position :

(COO)



TRAVELLING REPORT

Date :

Report To		
Employee Name	Aye Thanda Soe, Kyi Kyi Win, Aung Si Thu	
Position	DH, DH, Senior Section Head	
Department	Space Part, Unit, Service	
Business	PG	
Departure & Arrival	Departure Date And Time	Arrival Date And Time
	21, 12, 24	24, 12, 24
Total Days		
Trip Information	1. From MHL To Pyay	
	2. From Pyay To GBK	
	3. From GBK To YAN	
Purpose For Travelling		
Travel Date	Activities	Remark
22.12.24	Pyay customer visit.	- Pyay customer ဆရာတို့ က ခွဲခွဲကို ဖြေရှင်းပေးခဲ့ အကြံပြုပါသည်။
23.12.24	GBK customer visit.	- အိမ်က customer များ ဖြစ်တဲ့ Daw Paek များ သည်
24.12.24	GBK BR Ground stock checking. Knowledge Sharing Return to YAN. * Unit prospect - Shwe La Min (40 KVA) - Hotel Irrawaddy (100 KVA) - Mya Myint MO (400 KVA) - Ko Myo Min (500 KVA)	- ဘာသာရေး၊ ဝတ်ပြုမှု service တို့ကို အကြံပြုပါသည်။ - BR ပုံ relation ပျက်နေပြီး ဖြစ်သဖြင့် BU ဖြစ်လာဖို့ ဖြစ် ဖြစ်လျှင် ချိတ်ဆက်ပေးပါသည်။ - Service man များ ခေါ် အကျိုးရှိမှု၊ knowledge ထပ်ဖြည့်ပေး အကြံပြုပါသည်။

Reported by

Sign :

Name : Aye Thanda Soe

Position : DH

Checked by

Sign :

Name :

Position :

Approved by

Sign :

Name :

Position :

(DH/AGM/GM)

(COO)

24

YAN to MAW.

8.12.24

Pwint Phyu.

- Unit customer appointment (2 unit deal & 1 unit rent)
* Royal Ayar (350kVA), Shwe Baho (300kVA) & Hto Aung Kyar (200kVA)

19.12.24

Salin

- MTO customer visit & mic inspection
- U Ye Win (VP 220S), mic hour - 873h 12m
- U Maung Maung Nyunt (MC 220BS), mic hour - 1102h 7m
- U Khin Maung Htay (MC 200BS), mic hour - 1053h 27m
- * not use Genset, only use EPC.

20.12.24

- Unit customer appointment (morning)

- Kaung Kaung Hotel (2 unit)

- MC 220 AS - Need to change oil sensor & clean radiator. (3160h 42m)

- MC 66 AS - Need to do valve adjustment. (4663h 20m)

- Tea villa

- MW 55 PS - Need to clean radiator (1746h 42m)

- KB Kyaw Thet Maing

- MC 110 TS (4847h 23m)

- Magway Kabon

- MC 109 MS

- Pyae Phyo San

- MF 44 JS (1189 h)

- * Not use Genset, use Solar

- Ian Pya Kyal

- MY. 25 JS (2355 hr)

- * Fuel pipe leakage

- Thar Hla

- MF 22 JS (Need to do RS)

- Royal Megway

MC9088

* Use other filter.

* Own service

*

IBS PRIVATE school

* Machine Breakdown

* Use Solar Inverter

MAW Branch ground stock checking. (Closing Qty 83)

21.12.24

Aunglan

- Daw Khin May San

MC11088

- U Than Oo (Unit online inquiry customer appointment)

- Myint Mo San (Unit marketing)

12.24

Thazin Clinic

- MF 33 JS (3108 h 53 min)
- * Need to change air cleaner
- + Need to clean radiator.
- + Need to check valve adjustment.

Kyau Clinic

- MC 66 AS (2327 h 24 m)
- + Need to change air cleaner
- * Need to do RS

Family Swimming Pool

- MC 188 TS (2356 h 29 m)
- + Need to change crankshaft seal.

Shwe Min Thane

- MC 220 AS (3912 h 31 m)
- + Need to change air cleaner
- + Need to clean radiator.
- + Made AVR adjustment for overvoltage shutdown.

Hotel Irrawaddy

- MC 88 AS (3315 h 18 m)

Daw Kyi Kyi lein (Pauk Aye?)

- MW 08 PS
- * Need to change alternator fan
- MF 44 JS (1539 h 29 min)
- * Need to clean radiator.
- + Need to change tapped cover seal.

23.12.24

Aung Yin Pyan

- MC 60 TS

Mya Myin Moh

- MC 710 TS (1857 h 15 m)

Aung Naing This Sar

VP 550 3 c 2 units)

24.12.24

- Source Knowledge sharing

- Spare Part Ground stock checking

