










# TRAVELLING REPORT

Date: 28.12.24

Report To		
Employee Name	Aye Thanda Soe, Kyi Kyi Win, Aung & Thu	
Position	DH	
Department	Spec Prod, DH, Section Head	
Business	PG, Unit, Service	
Departure & Arrival	Departure Date And Time	Arrival Date And Time
	17.12.24	29.12.24
Total Days		
Trip Information	1. From YAN To MAW	
	2. From To	
	3. From To	
Purpose For Travelling	To know BR market condition, old customer visit and m/c inspection, BR & customer relation, how to support to get order	
Travel Date	Ground stock checking. Activities	Remark
17.12.24	Departure from YAN (6:00am) Arrived to MAW (6:00pm)	- Customer feedback is good.
18.12.24	- Go to Point Phyga	- Not have reminder card
19.12.24	- Go to salin - Come back to MAW.	- We advised to use the motor filter instead used other filter.
20.12.24	- MAW down town customer visit.	Unit prospect (8 units) + U. Thantoo (250KVA) + Shwe Nadi (250KVA) + U Hkun Hta (200KVA) + U Win Tun (100KVA) + U Shwe Win Tun (200KVA) + U Low Min (80KVA) + U Aung Toe (100KVA) + U Hday Win (80KVA)
21.12.24	- Go to Aunglan, Pyay	

Reported by  
 Sign :   
 Name : Aye Thanda Soe  
 Position : DH

Checked by  
 Sign :   
 Name : Aye Thanda Soe  
 Position : DH

Approved by  
 Sign :   
 Name : Aye Thanda Soe  
 Position : DH

(DH/AGM/GM)

(COO)



# TRAVELLING REPORT

Date : .....

Report To		
Employee Name	Aye Thundon Soe, Kyi Kyi Win, Aung Si Thu	
Position	DH, DH, Service Section Head	
Department	Spone Part, Unit, Service	
Business	PG	
Departure & Arrival	Departure Date And Time	Arrival Date And Time
	22.12.24	24.12.24
Total Days		
Trip Information	1. From ..... M.F.W. .... To ..... Pyay .....	
	2. From ..... Pyay ..... To ..... GBK .....	
	3. From ..... GBK ..... To ..... YGN .....	
Purpose For Travelling		
Travel Date	Activities	Remark
22.12.24	Pyay customer visit.	- Pyay customer ဆရာများက ချိန်ခွဲကို ပြင်ဆင်ပေးခဲ့ပြီး အကူပြုပါသည်။
23.12.24	GBK customer visit.	- အိမ်က customer များက ဖြစ်တဲ့
24.12.24	GBK BR Ground stock checking. Knowledge Sharing Return to YGN.  * Unit prospect - Shwe la Min (40 KVA) - Hotel Innowaddy (100KVA) - Mya Myint MO (400KVA) - Ko Myo Min (500 KVA)	- Daw Paik ဂျယ်သည် စက်မှုစီးပွားဝန်ထမ်းရေးရာဝန်ထမ်းများနှင့် ဆက်သွယ်ဆွဲနည်းများကို အကူပြုပေးခဲ့ပြီး ကတိပေးချက်များကို အကောင်အထည်ဖော်ပါသည်။ - BR နဲ့ relation ပျက်နေပြီး ဖြစ်သဖြင့် BU ဖွဲ့စည်းပေးပြီး ဖြည့်ဆည်းပေးရန် ဆက်ဆံပါသည်။ - Service man များ၏ skill, knowledge ထပ်မံဖြည့်ဆည်းပေးပါသည်။

Reported by  
 Sign :   
 Name : Aye Thundon Soe  
 Position : DH

Checked by  
 Sign :   
 Name :  
 Position :

Approved by  
 Sign :   
 Name :  
 Position :

(DH/AGM/GM)

(COO)



24

YAN to MAW

18.12.24

Paing Phyu

- Unit customer appointment (2 unit deal & 1 unit rent)  
\* Royal Ajar (350kVA), Shwe Baho (300kVA) & Htoo Aung Kyar (200kVA)

19.12.24

Salin

- MTO customer visit & mic inspection
- U Ye Win (VP 220S), mic hour - 873h 12m
- U Maung Maung Nyunt (MC 220BS), mic hour - 1102h 7m
- U Khin Maung Htay (MC 200BS), mic hour - 1053h 27m
- # not use Genset, only use EPC.

20.12.24

- Unit customer appointment (morning)
- Kaung Kaung Hotel (2 unit)
  - MC 220AS - Need to change oil sensor & clean radiator. (3160h 42m)
  - MC 66 AS - Need to do valve adjustment. (4663h 20m)
- Tea villa
  - MW 55PS - Need to clean radiator (1746h 42m)
- KB Kyaw Thet Aung
  - MC 110TS (4847h 23m)
- Magway Kabou
  - MC 109MS
- Pyae Phyoo San
  - MF 44 JS (1189 h)
  - \* Not use Genset, use Solar
- Lan Pya Kyal
  - MY. 25 JS (2355 hr)
  - \* Fuel pipe leakage
- Thar Hla
  - MF 22 JS (Need to do RS)

- Royal Magway

MC9088

\* Use other filter.

\* Own service

\*

IBS PRIVATE school

\* Machine Breakdown

\* Use Solar Inverter

# MAW Branch ground stock checking (closing aty 83)

21.12.24 Aunglan

- Daw Khin May San

MC11088

- U Than Oo (Unit online inquiry customer appointment)

- Myint Mo San (Unit marketing)

12.24

### Thazin Clinic

- MF 33 JS (3108 hr 53 min)
- + Need to change air cleaner
- + Need to clean radiator.
- + Need to check valve adjustment.

### Ryaco Clinic

- MC 66 AS (2327 h 24 m)
- + Need to change air cleaner
- + Need to do RS

### Family Swimming Pool

- MC 188 TS (2356 h 29 m)
- + Need to change crankshaft seal.

### Shwe Min Thamee

- MC 220 AS (3912 h 31 m)
- + Need to change air cleaner
- + Need to clean radiator.
- + Made AVR adjustment for overvoltage shutdown.

### Hotel Irrawaddy

- MC 88 AS (3375 h 18 m)

### Daw Kyi Kyi Lwin (Pauk Kyi?)

- MW 08 PS
- + Need to change alternator fan

- MF 44 JS (4589 h 29 min)

- + Need to clean radiator.
- + Need to change tapped cover seal.

23.12.21 Doung Yin Pyan

- MC 60 TS

Miya Myin Moh

- MC 110 TS (1857 h 15 m)

Aung Naing This Sar

VP 5503 (2 units)

24.12.21

- Source Knowledge sharing

- Spare Part Ground stock checking